

# BOIL WATER ORDER

Loss of pressure in Pine Rest East Mobile Home Park ( Tan Bark Dr., Dutton Ct., Vermont St., and Shelburne St.) served by Greater Plattsburgh Area Water District  
PWS ID # NY0900220

## BOIL YOUR WATER BEFORE USING

**CUSTOMERS OF PINE REST EAST MHP ONLY ARE HEREBY ORDERED BY THE CLINTON COUNTY HEALTH DEPARTMENT TO BOIL ALL WATER FOR DRINKING AND CULINARY PURPOSES.**

---

### DIRECTOR OF ENVIRONMENTAL HEALTH

**On 9/9/2011 a section of the park lost water pressure in order to repair a water line leak affecting residents on Tan Bark Dr., Dutton Ct., Vermont St., and Shelburne St.** When the distribution pipes and mains lose pressure it increases the chance that untreated water and harmful microbes could enter the system.

**DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST.** Bring all water to a boil, let it boil for one minute, and let it cool before using, or use bottled water certified for sale by the New York State Department of Health. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes, and food preparation **until further notice**. Boiling kills most bacteria and other organisms in the water.

Harmful microbes in drinking water can cause diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, some elderly, and people with severely compromised immune systems. The symptoms above are not just caused by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

#### **What is being done?**

Repairs have been made to the water system. Then the system must be flushed and disinfected according to AWWA standards; a minimum working pressure of 20 psi and a minimum chlorine residual of 0.2 mg/L must be restored. Two check samples must be taken 24 hours apart from the affected area and both must be absent of total coliform bacteria. You will be informed when tests confirm that no harmful bacteria are in the system and you no longer need to boil your water.

For more information, please contact Bonnie Dutton at 561-8939 or the Clinton County Health Dept. at 518-565-4870.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail*